

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Pressure Switch**

with type designation(s)

KPS 31, KPS 33, KPS 35, KPS 37, KPS 39, KPS 43, KPS 45, KPS 47

Issued to

Danfoss A/S**Nordborg, Syddanmark, Denmark**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Location classes:**

Temperature	B
Humidity	B
Vibration	B
EMC	N/A
Enclosure	B/IP67

Issued at **Høvik** on **2019-02-27**for **DNV GL**This Certificate is valid until **2024-02-10**.DNV GL local station: **Fredericia**Approval Engineer: **Nils Jarem****Marta Alonso Pontes**
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-007157-4**
Certificate No: **TAA000026C**

Product description

Type	Range [bar]	Differential [bar]	Connection
KPS 31:	0 - 2.5	0.1	G 1/4, G 3/8 A
KPS 33:	0 - 3.5	0.2	G 1/4, G 3/8 A
KPS 35:	0 - 8	0.4 - 1.5	G 1/4, G 3/8 A
KPS 37:	6 - 18	0.85 - 2.5	G 1/4, G 3/8 A
KPS 39:	10 - 35	2 - 6	G 1/4, G 3/8 A
KPS 43:	1 - 10	0.7 - 2.8	G 1/4
KPS 45:	4 - 40	2.2 - 11	G 1/4
KPS 47:	6 - 60	3.5 - 17	G 1/4

Output: 1 c/o - contact
Rating: 10A 440V AC-1, 6A 440V AC-3, 4A 440V AC-15

Place of manufacture

Danfoss Poland Sp. z o.o..
PL-05-825 Grodzisk Mazowiecki
Poland

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Data sheet: [IC.PD.P10.I6.02 | 520B7855](#)
Drawing: [060-9201 ver.01](#)
Test Report: [No. 23665 dated 1976-09-16;](#)
[No. 8174027 dated 1981-11-02](#)

[Type approval renewal assessment report for GL 91481-76HH, DNV GL Gdynia 2018-02-26](#)

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Job Id: **262.1-007157-4**
Certificate No: **TAA000026C**

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE