

Pressure Supervisory Switches

These switches are operated by supervised fluid pressure applied to a built-in bellows, diaphragm or Bourdon tube which is mechanically linked to the switch member. The normal arrangement provides for the switch contacts to open automatically if the supervised pressure is reduced to a potentially unsafe point. Other equipment then acts to shut down the combustion process, as applicable. For alarm or other purposes, the switch action may be the reverse.

Switches having a means of adjusting the operating pressure range require cover removal to accomplish adjustment.

When ordering, specify type, model, maximum operating pressure, temperature, fluid handled, electrical characteristics and operating pressure desired.

Pressure Supervisory Switches for Fuel Gas and Ventilating or Combustion Air

These switches may also be used as airflow interlocking switches and are recommended for safety cock applications.

Types KP 34, 35, 36, 37, Types KPI 35, 36, 38

Type KP followed by 34, 35, 36 or 37, with manual or automatic reset, adjusting range -2.9 to 300 psi (-0.2 to 20.7 bar) with fixed or adjustable differential. Type KPI followed by 35, 36 or 38, automatic reset, adjusting range -2.9 to 406 psi (-0.2 to 28 bar) with fixed differential.

Special Conditions of Use:

A supervisory switch can only be used with automatic reset when used in conjunction with an FM Approved burner management system.

Series KPI, when installed with hazardous live voltage at the relay, must include a suitable method of strain relief on the cable.

Company Name:	Danfoss SP zoo
Company Address:	Ul, Chrzanowska 5A, 05-825 Grodzisk Mazowiecki, Poland
Company Website:	http://www.danfoss.com/Poland
Listing Country:	Poland
Certification Type:	FM Approved

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T:781 762 4300 F:781-762-9375 www.fmaprovals.com

June 28, 2017

Gert Skovgaard Linderod
Danfoss A/S
Nordborgvej 81
6430 Nordborg,
Denmark

Subject: Final Letter Report - Initial Audit at Danfoss Industries Pvt Ltd
Customer ID: 113796-1
Project ID: 3062235


Dear Mr. Skovgaard Linderod,

This final letter report is to serve as confirmation that Danfoss Industries Pvt Ltd has successfully completed the required audit requirements at A-19/2 SIPCOT Industrial Growth Center, Oragadam V 602105 Tamilnadu P.O. Box 602105 Tamilnadu India. At this time, FM Approvals authorizes the manufacturing and marking of product at this location in accordance with audited product approvals. This location will be subject to future surveillance audits to ensure product compliance.

The issuance of this final letter report is considered to be the completion of the subject program and the project will be closed. You will be billed for work performed to date.

If you have any questions please feel free to contact me at 781-255-4878 or email me at ignazio.pendola@fmaprovals.com.

Sincerely,



Ed Pendola
Quality Customer Service Manager
Tel: 781-255-4878
Email: ignazio.pendola@fmaprovals.com



Robert Lovell
Operations VP, Manager of Auditing and
Quality Assurance
Tel: 781-255-4820
Email: robert.lovell@fmaprovals.com

